

Note: roof covering & underlayment as req'd by code.

Note: Spline to be of material conforming to DOC PS2, min thickness 7/16".

8d box (0.113) nails @ 3" o.c. both sides of panel joint or equivalent. Top side of panel only.

R-Control SIP.

SIP Tape or equivalent vapor retarder located interior or exterior per climate conditions or code requirement.

Design as req'd by engineer. Pre-drill flange for screw application.

Surface spline (see SIP-102).

R-Control Do-All-Ply 1/2" diameter continuous bead.

Structural support member (steel joist).

SECTION

Scale: NTS

Updated 3-26-12

R-Control® SIP

TITLE: Surface Spline
At Steel Joist

NO.
SIP-133f